



Wels, June 06th 2016

G83 AND G59 COMPLIANCE

Fronius International GmbH

confirms that all parameters in the Setup GB for compliance with G59 and G83 are identical. With the GB Setup these parameters are set in the inverter. The inverter exactly behaves according to both requirement documents.

The difference is, that the commissioning process for generation units $\leq 16A$ is easier in GB (Fit and Inform), and the compliance test protocol has some formal differences. This does not affect the inverter behavior.

- / G83 is required for generation units $\leq 16A$
- / G53 is required for generation units $> 16A$

Fronius International GmbH

Solar Energy Division
Froniusplatz 1
A-4600 Wels

A handwritten signature in blue ink, appearing to read "Thomas Mühlberger".

DI Thomas Mühlberger
Head of Solution Management