

Wels, 09.05.2022

## NOISE EMISSION FRONIUS PRIMO GEN24 3.0-6.0

### Fronius International GmbH

hereby confirms the following parameters:

	Sound power level	Sound pressure
<b>Fronius Primo GEN24 3.0</b>	50.0 dB(A) (ref. 1pW)	42.0 dB(A) (ref. 20µPa)
<b>Fronius Primo GEN24 3.6</b>	50.0 dB(A) (ref. 1pW)	42.0 dB(A) (ref. 20µPa)
<b>Fronius Primo GEN24 4.0</b>	50.0 dB(A) (ref. 1pW)	42.0 dB(A) (ref. 20µPa)
<b>Fronius Primo GEN24 4.6</b>	50.0 dB(A) (ref. 1pW)	42.0 dB(A) (ref. 20µPa)
<b>Fronius Primo GEN24 5.0</b>	50.0 dB(A) (ref. 1pW)	42.0 dB(A) (ref. 20µPa)
<b>Fronius Primo GEN24 6.0</b>	50.0 dB(A) (ref. 1pW)	42.0 dB(A) (ref. 20µPa)

Acoustic measurements can provide several parameters. The parameters typically used are the sound power level and the sound pressure level.

The sound power level is the sum of the noise radiated over the entire surface of the device.

The sound pressure level is typically measured at 1 m in front of the enclosure and represents the noise exposure at that location under specific environmental conditions.

### Fronius International GmbH

Business Unit Solar Energy  
Froniusplatz 1  
4600 Wels



Bernhard Kossak, MSc  
Head of Solution Management